

## WHAT DEFINES THEM?


REI120 and REI180 fire rated gates are available with horizontal sliding. The field of application includes the closure of large openings and/or special usage conditions in the dimensions requested by the customer. Gates are supplied with leaves made with flush panels of insulated sheet metal, top tubular tracks, protective carters, counterweights, thermal or electromagnetic fuses and finished with a base coat or RAL colors, plus other accessories required for the correct functioning of the product.

### Standards

The gates are certified in accordance with UNI 9723 standard in compliance with the current ministerial provisions in force.


### Opening direction

The opening direction needs to be specified when the order is placed.



Two-leaved gates available in the following classes:

REI 120



### NOTE

Fire rated gates require careful design because of their dimensions and special functions. Every installation site should be measured and checked for vertical alignment of the walls and gradients of the flooring. Particular care must be taken to check for protrusions or blockages that might hinder the

Sliding gates available in the following classes:

REI 120 REI 180



### ATTENTION

Fire compartmentalization elements should always be used properly. They are only designed for installation in spaces and constructions that are vertically aligned and flush.

Interior compartmentalization is possible for areas only which are not subject to strong air currents. Installation to be executed by specialized technicians only. For special applications consult with our technical office.

The holding system for the gate is chosen by the customer to conform with their own worksite needs and the anti-fire design (thermal fuse or electromagnet).

operation or free movement of the gates. Given the considerable weight of gates, the bearing capacity of the walls and crossbeams involved should be checked for the mounting of top guide tracks and overlapping labyrinths.